Combined system providing an **area elastic deformation**, made of linoleum fully glued on a birch plywood sub construction.

The system, at least, **41.2mm thick**, is composed of polyethylene film,  $80\text{kg/m}^3$  density PU foam with engineered bumpy texture, **18mm thick 100% birch plywood board** with **tongue & groove interlocking system** and linoleum top layer.

The **fire resistance** according to EN13501-1 should be at least **CfI-s1**.

The linoleum top layer, 3.2mm thick should be **certified cradle to cradle silver**. Its emission rate of volatile organic compounds in air is very low, measured after 28 days according to EN standard 16516. Close to zero emission (quantification limit), **TVOC**, **TSVOC** and **formaldehyde emissions are below 10 µg/m³**.

The linoleum top layer should be 100% recyclable. The clean off-cuts can be collected, recycled and reused in the production of linoleum floor coverings through Restart® program or similar.

The product must comply with REACH program recommendation.

Product warranty should be equal or superior to 10 years.

Before installing the floor coverings, a slab check is mandatory: holes and bumps should not exceed 6mm, under the 3m ruler.

The temperature should be high enough to allow the installation in good conditions (see manufacturer's recommendations). All fees connected to the heating of the gyms will be imputed to the owner of the building.

The installation should be performed in accordance with **local requirements** and in conformity with **manufacturer's installation guide recommendations**.

## Available documentation & certificates

- Technical datasheet
- Multi-language DoP (Declaration of Performance)
- EN 14904 certificate of compliance
- Reaction to fire test report
- · Installation guide
- · Maintenance guide

